



INQUIRY NUMBER : 403606
SUPPLEMENT : No 1
DATE OF SUPPLEMENT: 25-05-16

Material: MULTISERVICE SWITCH DIVICES

Present Supplement No 1 to the above Inquiry, is issued by the following reasons :

1. The closing date of the Bid is extended as follows:

New closing date of the Bid: 14.06.16 time: 10:00 a.m.

2. The following are clarified:

- 2.1 4. Network topology. The second paragraph of chapter 4 is supplemented:

The offered MultiService MUX equipment must be able to operate in a multivendor network environment, with E&M, RS232, E1 nx64kbps, E1 framed or unframed, STM-1/STM-4/STM-16 (~2.5 Gbit/s) or alternatively STM-1/STM-4/10 Gbit/s equivalent to Carrier Ethernet or MPLS-TP protocols.

- 2.2 5.7 Teleprotection. The following is clarified:

According to the specification T- 2101- A, the distance Teleprotection must be able to support analogue and digital / optical interfaces. These interfaces are usually offered in different boards. At this tender only the analogue interface is requested as stated in the order list (6.7 System Configuration): (Teleprotection card - of 4 commands).

- 2.3 9. Technical evaluation. The following is clarified:

The technical evaluation test will be performed at Rouf premises for a period of one month (approximately).

3. All other terms of the initial Inquiry that are not modified through present Supplement No1, remain in full force and effect.