



February 2013

TECHNICAL DESCRIPTION TD-63/4
420KV OUTDOOR, KNEE TYPE SINGLE POLE, AC DISCONNECTOR WITH
ELECTRIC MOTOR OPERATING MECHANISM
(DESIGNATED BY IPTO S.A AS No 403.1)

I. SCOPE

This technical description covers IPTO requirements with regard the design features, rated characteristics and testing of 420 KV, single-pole, knee type AC disconnectors equipped with an electric motor operating mechanism.

II. KEYWORDS

AC disconnectors, disconnecting switches, isolators, knee type disconnectors.

III. STANDARDS

The disconnector shall be in accordance with IEC-62271-102 & IEC-60694 standards. Furthermore the disconnector's cylindrical post insulators shall be in accordance with IEC-60273 & IEC-60168 standards.

IV. USE

The disconnector is to be used in the buses arrangements and also in the bus ties arrangements of the ehv substations.

V. SERVICE CONDITIONS

- | | |
|------------------------------|--|
| 1. Installation | : Outdoors |
| 2. Ambient temperature range | : Maximum + 45°C |
| | : Minimum - 25°C |
| 3. Altitude | : Up to 1000m above
sea level |
| 4. Relative humidity | : ≤ 95% |
| 5. Ice coating | : 20mm maximum |
| 6. Pollution level | : moderate to heavy depending
on location |
| 7. Wind speed | : 150Km/h |
| 8. Other conditions | : Snow and fog |

VI. IPTO 400 KV ELECTRICAL SYSTEM CHARACTERISTICS

- | | |
|--|--|
| 1. Nominal Voltage | : 400KV |
| 2. Maximum Operating Voltage | : 420KV |
| 3. Lightning impulse withstand voltage | : 1550KV |
| 4. Short circuit level | : 40KA |
| 5. Number of phases | : 3 |
| 6. Nominal Frequency | : 50 Hz |
| 7. Earthing (grounding) method | : The 400KV system is solidly earthed (grounded) |
| 8. Auxiliary voltages | : 220V DC and 220V AC, 1Φ or 400V AC 3Φ. |

VII. DISCONNECTOR REQUIRED DESIGN FEATURES

1. Type

The disconnector shall be single-pole of knee type, with a two (2) piece folding arm (blade) and with two (2) cylindrical post insulators (column) and one rotating insulator (insulated rod). The two (2) cylindrical post (column) insulators shall be installed on a common steel base on which possible metallic supports, for the connection of each insulator's base to the disconnector's common base, to be adapted. The rotating insulator shall rotate in order to transmit the motion to the arm (blade).

The layout arrangement of the disconnector is shown in drawing No. 403.1/2.

2. Arm (blade) function

The arm which shall consist of two pieces, in the open position shall fold upon itself in a vertical position.

3. Material of the arm (blade)

The two pieces arm (blade) of the disconnector shall be either from extra heavy tubular aluminium or extra heavy tubular aluminium alloy.

4. Characteristics of the fixed and movable contacts

a. Both the fixed and the movable (arm) contacts shall be replaceable.

b. Both contacts shall be self-cleaning and of such design so that short circuit currents increase their contact pressure.

c. The movable (arm) contacts shall be of the finger type.

d. The contacts in the closed position shall be able to withstand wind forces, seismic forces, forces exerted by the tension of conductors and also forces due to temperature variations without being separated.

5. Type of material of the fixed and movable contacts

Both contacts shall be of silver plated copper.

6. Base frame of the insulators of the disconnector

The common steel base and the possible metallic supports for each of the two cylindrical post (column) insulators shall be made of hot dip galvanized steel. The common base shall have a height of 150mm.

7. Terminals

The disconnecter shall be fitted with two (2) aluminium terminals of orthogonal shape. These terminals shall have dimensions as indicated in the attached drawing No. 403.1/2.

8. Mounting of the disconnecter

The disconnecter shall be installed on a steel structure which shall be provided by IPTO S.A and which is explicitly shown in drawing No. 403.1/1.

9. Earthing (grounding)

The disconnecter shall be equipped with a flexible tin plated copper strip of 240mm² in cross-section for the purpose of using it to earth the disconnecter to the earthing (grounding) mat of the substation.

10. Dimensions of disconnecter

- a. The distance between the two (2) post (column) insulators of the disconnecter shall be 4000mm ($\pm 5\%$).
- b. The disconnecter shall be installed on a steel support structure of 3000mm in height, which shall be provided by IPTO S.A.

11. Corona rings

The two cylindrical post insulators of the disconnecter shall be equipped with corona rings in order to level off the electric field at the rough edges of the disconnecter or to eliminate concentrated electrostatic induction at the edges of the disconnecter.

12. Transmission motion system of the disconnecter

- a. The transmission motion system of the disconnecter shall consist of a vertical bare rod and a possible insulated rod. The whole system must be suitable, along with the two (2) cylindrical post(column) insulators and their base frame, to be mounted on steel support structure (not part of the supply) of 3000mm in height, as indicated in the attached drawing No. 403.1/1 of this hereby technical description.
- b. In case of accidental rod dismantling, the blade (arm) of the disconnecter must not be moved from the position found.
- c. The transmission motion system must be designed for smooth noiseless and precise operation, and to avoid any undesired operations.
- d. The base of the rotating insulated rod must be auto lubricated and protected against corrosion and moisture.

13. Counterbalancing springs

Counterbalancing springs shall be used in order to balance the weight of the movable parts and the opening and closing of the disconnecter. All counterbalancing springs must be isolated from the main path.

14. Type of metallic materials used for the non-current parts of the disconnecter.

The non-current carrying metallic parts of the disconnecter can be made either of hot dip galvanized steel or stainless steel.

Cast iron can be used only in places where the applied forces are not of important magnitude. The cast iron shall also be hot dip galvanized.

15. Type of material of the connection components.

All bolts, nuts and washers which are used in current carrying parts of the disconnecter shall either be of stainless steel or bronze.

All bolts, nuts and washers used in the non-current carrying parts of the disconnecter shall be of hot dip galvanized steel.

16. Operating Mechanism of the disconnecter

- a. The operating mechanism of the disconnecter shall be driven by an electric motor, for the rotation of the axis via metallic gear wheels.
- b. The electric motor operating mechanism shall be of the reversible motion type.
- c. The electric motor operating mechanism must be capable of being operated electrically locally and also capable of being tele-operated from a remote place. Furthermore, the mechanism shall include provision for manual operation in case of an emergency.
The local electrical and remote electrical command for the operation of the disconnecter is given by a pulse of 200ms in duration and for this reason a latching function shall be produced to the supply circuit of the motor unit the completion of the motion of the operating mechanism.
In case during the execution of the motion, the supply voltage of the motor is lost or the interlocking coil is deenergized, then the movement of the disconnecter shall be stopped and the disconnecter shall remain in the position it had when it stopped. After the supply voltage is restored (or the re-energization of the interlocking coil), a new command must be given in order the movement to be completed.
- d. The motor of the operating mechanism shall be 3 Φ , 400V AC, or UNIVERSAL DC commutator type of 220V DC or 1ph 230V AC (via rectifier).
- e. The manual emergency operation shall be carried out via rotary motion and reduction gear with a hand-handle which shall be removable. The electric control circuit shall be placed automatically out of service when the hand-handle is inserted for the manual emergency operation.
The parts of the handle which come in contact with the human hands shall be covered with insulating material.
The insertion of the removable hand-handle to the housing shall be possible through an opening in the outer surface of the housing of the operating mechanism. This opening shall be capable of being secured with a padlock. The removable handle shall be kept inside the housing of the operating mechanism.

f. The motor operated mechanism shall be equipped with a rotary selector switch which shall allow the following four (4) modes of operation:

- Position 1 : Manual operation. Operation only via the hand-handle
- Position 2 : Local operation-Local electrical control
- Position 3 : Tele-operation. Electrical operation from a remote place
- Position 4 : Off. No electrical or manual operation is allowed

The selection of any one of the above positions shall exclude the possibility of operation form in any other position. The selector switch shall be capable of being locked of the selected positions with a lock. In the off position, the disconnecter is locked in this position and:

- There is no access to the opening of the housing for the hand-handle
- All voltage commands to the motor are isolated (cut-off)
- The transmission motion system is mechanically blocked from the motor towards the reduction gear.

- g. No sliding disks or electrical brakes are allowed for the transmission of torque to the transmission motion mechanism or to the blade (arm) in order to cease motion at the end of the blade travel and to avoid over-travel.
- h. The immobilization of the motor axis shall be controlled electrically by limit switches. For extra safety reasons only, mechanical stops may also be used.
- i. The mechanism shall be equipped with limit switches which shall interrupt the operation of the electrical motor when the disconnecter's blade has reached its final position in both positions (opened-closed).
- j. The electrical motor operating mechanism shall be equipped with an interlocking coil, of coil voltage of 220V DC, which shall be used for electrical interlocking between the disconnecter and its corresponding circuit breaker. The interlocking coil in the deenergized state shall prevent the electrical operation of the mechanism by means of an auxiliary contact, and the manual operation by means of a mechanical blocking.
- k. The electric motor operating mechanism shall be equipped with the following auxiliary contacts of high reliability as to ensure the exact status of the disconnecter:

- Seven (7) NO contacts of type A
 - Seven (7) NC contacts of type B
 - Two (2) NO contacts of type C
 - Two (2) NC contacts of type D
- l. The signal for “Disconnecter is closed” shall be given only after complete closing which means that a short circuit current can run through the disconnecter, while the signal for “ Disconnecter is open” shall be given only after the complete opening when the isolating distance is sufficient to withstand with success the required dielectric tests.
 - m. All control cables of the operating mechanism shall be of cross section of 1.5mm^2 at least and shall bear proper markings. However the terminal strips shall be suitable for 8mm^2 cross section conductors.
 - n. The housing of the operating mechanism shall be either from stainless steel or hot-dip galvanized steel or aluminum alloy.
 - o. The degree of the protection of the housing shall be IP 42D, as per IEC-60529.
 - p. The operating mechanism shall be equipped with a spare terminal block of at least eight positions. The terminal block shall be suitable for 8mm^2 size conductors.
 - q. The housing of the operating mechanism shall be equipped with anti-condensation heater or heaters, controlled by a thermostat. The supply voltage to the heaters shall be 1Φ , 220V AC.
 - r. All electric circuits of the mechanism shall be suitable for 220V DC and shall be protected by miniature circuit breakers or fuses.
 - s. The housing of the operation mechanism shall allow cable entrance from its bottom (IPTO cables).
 - t. The housing of the operating mechanism shall be installed (mounted) on the steel support structure, which shall be provided by IPTO as indicated in drawing No. 403.1/2.
For this reason all, bolts, nuts, brackets and any other mounting component must be part of the supply.
All connection parts, for example bolts, nuts, brackets, etc must be either from stainless steel or hot-dip galvanized steel.

VIII. DISCONNECTOR REQUIRED RATED ELECTRICAL AND OTHER CHARACTERISTICS

1. Number of poles	: One (1)
2. Installation	: Outdoors
3. Rated Voltage	: 420KV
4. Rated insulation levels	
a. Power frequency withstand voltage	
- Phase to earth	: 620KV rms
- Across the isolating distance	: 800KV rms
b. Rated switching impulse withstand voltages, dry	
-Across the isolating distance	: 900 (+450) KV, peak
c. Rated switching impulse withstand voltage, wet	
- Phase to earth	: 1050 KV, peak
d. Lightning impulse withstand voltage	
- Phase to earth	: 1550KV peak
- Across the isolating distance	: 1550 (+315) KV, peak
5. Rated frequency	: 50 Hz
6. Rated normal current	: 3150 A
7. Rated short-time withstand current	: 40 KA rms
8. Rated peak withstand current	: 100 KA peak
9. Rated duration of short circuit	: 3 sec
10. Rated static mechanical terminal load	
- Straight load	: 2000N at least
- Cross-load	: 660N at least
- Vertical Force	: 1500N at least
11. Thickness of ice coating for which operation shall be possible	: 20 mm
12. Type of conductors used for the connection of the disconnecter	: Flexible
13. Mechanical endurance class	: M1 (2000 operating cycles)

IX. SUPPORT INSULATORS REQUIRED CHARACTERISTICS

A. CYLINDRICAL POST (COLUMN) INSULATORS

1. Type	: Outdoor solid core cylindrical post insulators with external metal fittings
2. Material of the cylindrical post insulators	: Porcelain
3. Color of the porcelain	: Gray
4. Designation of the insulators as per IEC-60273	: C12.5-1550
5. Switching impulse withstand voltage wet	: 1050 KV peak
6. Lightning impulse withstand voltage	: 1550KV peak
7. Height of the post insulator	: 3350mm ± 4.5 mm
8. Creepage distance	: 10500mm
9. Failing load	
a. Bending	: ≥ 12500N
b. Torsion	: ≥6000Nm
10. Bottom metal fitting pitch circle diameter	: 325mm
11. Maximum nominal diameter of insulating part	: 450mm
12. Top metal fitting pitch circle diameter	: 225mm

B. ROTATING (TORSIONAL) INSULATOR

1. Type	: Outdoor cylindrical hollow insulator.
2. Material of the insulator	: Porcelain
3. Color of the porcelain	: Gray
4. Switching impulse withstand voltage wet	: 1050KV, peak
5. Lightning impulse withstand voltage	: 1550KV, peak
6. Height of the insulator	: 3350mm ± 4.5mm
7. Creepage distance	: 10500mm
8. Maximum nominal diameter of the insulating part	: As determined by the design of the manufacture and the requirements of this hereby technical description.
9. Failing load	
a. Torsion	: ≥2000Nm

X. TESTS

The disconnecter shall be subject to the following tests.

A. Routine tests

The routine tests shall be carried out on all disconnectors of the order.

1. Dielectric test on the main circuit of the disconnecter.

Power frequency voltage test (dry)

The test voltage shall be 620 KV rms for phase to earth and 800KV rms across the isolating distance. The test conditions shall be in accordance with table 6 of IEC 62271-102.

Alternatively, the power frequency voltage withstand test may be omitted if the dimensions between the conductive parts, across open contacts and between conductive parts and the frame – are checked by measurements. Bases for the checking of dimensions shall be the dimensional drawings which are part of the type test report, if such report exists, otherwise this alternative option shall not be taken into consideration.

2. Dielectric test on auxiliary and control circuits

The test voltage shall be 1 KV with duration of 1 minute.

3. Measurement of the resistance of the main circuit

The test current shall be between 50A and the rated nominal current.

The measured resistance shall not exceed 1.2 R_u where R_u is equal to the resistance measured before the temperature rise test.

4. Design and visual checks

The disconnectors shall be checked to verify that they comply with this hereby technical description.

B. Special Tests

The special test shall be carried out only on one (1) disconnecter of the order because of the assembly complexities involved.

1. Mechanical operating tests

The tests shall be performed without voltage or current flowing through the main circuit. The test program shall consist of five close-open operating cycles at minimum supply voltage and five close-open operating cycles at maximum supply voltage.

The test shall be performed on a completely assembled disconnecter.

C. Type Tests

1. Dielectric tests

In the closed position, the tests shall be performed in conditions 1, 2 and 3 of table 9 of IEE 60694. In the open position the tests shall be performed as described below:

- a. Power frequency voltage test
 - Test voltage : 620 KV rms for 1min for phase to earth.
: 800 KV rms for 1 min across the isolating distance
 - Conditions : Dry

- b. Switching impulse voltage test
 - Test voltage : 900 (+450) KV of both polarities across the isolating distance under dry conditions
: 1050KV of both polarities for phase to earth under wet conditions.
 - Switching impulse shape : 250/2500 μ s

- c. Lightning impulse voltage test
 - Test voltage : 1550KV peak of both polarities for phase to earth
: 1550(+315)KV peak across the isolating distance
 - Lightning impulse shape : 1.2/50 μ s
 - Conditions : Dry

2. Test on auxiliary and control circuits

- a. Impulse voltage withstand test
Test voltage : 5KV

- b. Power frequency voltage withstand test
Test voltage : 2KV for 1min

Each of the above tests shall performed between the auxiliary and control circuits connected together as a whole and the frame of the disconnector.

3. Radio interference voltage (r.i.v) test

The test shall be applied as follows:

- a. In closed position between terminals and earthed frame
Level of radio interference at 267 KV : $\leq 2500\mu$ V

4. Temperature-rise test

- Test current : 3150A
- Test frequency : 50 HZ +2%, -5%
- Test duration : Up to the time at which the increase of temperature rise does not exceed 1K in 1h

5. Short-time withstand and peak withstand current test

- Short-time test current : 40 KA rms
- Peak withstand test current : 100 KA peak
- Test frequency : 50 Hz \pm 10%
- Test duration : 3 sec

6. Operating and mechanical endurance tests

The mechanical endurance test shall consist of 2000 close-open operations with 50% of the rated static terminal load applied at both sides of the disconnector but in opposite directions, without voltage on or current through.

7. Operation test under severe ice conditions

The test shall be conducted with class 20 of ice coating (20mm of ice coating).

XI. TESTS FOR THE DISCONNECTOR'S INSULATORS

The disconnector manufacturer is obliged to present to the IPTO inspector, when the inspector is at the manufacturer's premises for the inspection and testing of the disconnectors, the following routine, sample and type test insulator certificates. Type test certificates are not required to be presented, if they have been submitted in the technical offer of the inquiry and have been found to be satisfactory.

All tests shall be in accordance with IEC-60168.

A. Routine tests

1. Visual inspection
2. Mechanical tests
The tests shall consist of:
 - a. Bending test and
 - b. Torsion test

B. Sample tests

Sample tests shall be carried out after the routine tests on a few numbers of insulators of the order selected, at random.

1. Verifications of dimensions
2. Temperature cycle test (This prior to the mechanical failing load test)

3. Mechanical failing load test (Bending, tensile, torsion and compression)
4. Porosity test
5. Galvanizing test

C. Type Tests

1. Dry lightning impulse withstand voltage test
2. Wet switching impulse withstand voltage test
3. Wet power – frequency withstand voltage test
4. Mechanical failing load test

XII. NAMEPLATES

The nameplates for the disconnecter, and for the operating mechanism, shall be of non-corrosive material, visible from ground and shall bear the following information:

	Disconnecter	Operating Mechanism
Manufacturer	✓	✓
Type	✓	✓
Serial Number	✓	✓
Year of Manufacture	✓	✓
Rated Voltage	✓	
Rated Lightning Impulse withstand voltage	✓	
Rated normal current	✓	
Rated duration of short circuit	✓	
Rated supply voltage of auxiliary circuits		✓
Mechanical endurance class	✓	
Mass	✓	✓

XIII. DATA WHICH MUST BE SUBMITTED BY ALL BIDDERS

1. Outline drawing of the disconnecter, in which the physical dimensions of the disconnecter are clearly depicted.
2. Brochures, technical pamphlets and any other information which is deemed necessary for the technical evaluation process.

3. All bidders are required to answer all items of **Attachment “A”**. Failure to comply or partial filling of the attachment will constitute sufficient reason for rejection of the offer.
4. Any test certificates for the type tests specified in this hereby technical description. Acceptance or not of these certificates lies on **IPTO** judgment.
5. A drawing indicating the disconnecter on its base frame with complete dimensions.
6. A preliminary drawing indicating mounting of the disconnecter, along with its operating mechanism on the steel support structure, which shall be supplied by **IPTO**. Failure to comply with this request will result in rejection of the offer.

XIV. DATA WHICH MUST BE SUBMITTED BY THE SUCCESSFUL BIDDER

1. Complete schematic and wiring drawings of the disconnecter, for approval before the construction of the disconnecter.
2. Complete physical drawings of the disconnecter, indicating all dimensions details, for approval before the construction of the disconnecter.
3. A drawing indicating the disconnecter on its base frame.
4. Maintenance and assembly instructions in detail for the disconnecter.
5. A drawing indicating mounting of the disconnecter, along with its operating mechanisms, on the steel support structure, which will be supplied by ADMIE.

XV. WARRANTY

The supplier must provide a warranty of two (2) years, beginning from the date of delivery of the disconnecter , for damages due to faulty design, or due to unreliable components, or due to combination of the two.

XVII. PACKING

Each disconnecter must be delivered packaged as follows:

1. Insulators in a separate wooden box.
2. Live parts of the disconnecter in a separate wooden box.
3. Operating rods of disconnecter tied together on a wooden box.
4. Disconnecter’s operating mechanism in a separate wooden box or alternatively, items 2, 3 and 4 as listed above in a robust wooden box and the insulators in a separate robust wooden box

ATTACHMENT "A"
420 KV OUTDOOR, KNEE TYPE, SINGLE POLE, AC DISCONNECTOR
WITH ELECTRIC MOTOR OPERATING MECHANISM (403.1)

All bidders must provide the following data. Failure to comply in full, shall constitute sufficient reason for rejection of the offer.

1. Type :.....
.....
.....
.....
2. Manufacturer :.....
3. Ambient temperature range during operation :.....
4. Indicate the number of pieces that the arm (blade) of the disconnecter consists of :.....
5. Are the fixed and movable (arm) contacts replaceable :.....
6. Are both the fixed and movable contacts self-cleaning and of such design so that short circuit currents increase their contact pressure? :.....
7. Are the movable contact of the finger type :.....
8. Can the contacts in the closed position withstand wind forces, seismic forces, forces exacted by conductors and also forces due to temperature variations without being separated ? :.....
9. Type of material of the fixed and movable contacts :.....
10. Indicate height of the steel base frame? :.....
11. Is the base frame of the disconnecter of hot-dip galvanized steel? :.....

12. Type of material of the terminals of the disconnecter and their dimensions :.....
.....

13. Indicate method of mounting of the disconnecter on its base frame :.....
.....
.....

14. Describe how the disconnecter is earthed :.....
.....
.....
.....

15. Indicate the distance between the two column insulators of the disconnecter :.....

16. Are the two column insulators of the disconnecter equipped with corona rings :.....

17. Indicate the components of the transmission motion system of the disconnecter :.....
.....
.....

18. In case of accidental rod dismantling, can the blade (arm) remain in the position found? :.....
.....
.....

19. Is the transmission motion system smooth and noiseless and of precise operation? :.....

20. Is the base of the rotating insulated rod auto lubricated and protected against corrosion and moisture? :.....
21. Is the disconnecter equipped with counter balancing springs ? :.....
22. Are the balancing springs isolated from the main path? :.....
23. Type of material of the non-current carrying parts of the disconnecter :.....
24. Type of material of the connection components :.....
25. Disconnecter's operating mechanism characteristics
- a. Is the operating mechanism of the disconnecter electric motor operated? :.....
 Are metallic gear wheels used for the rotation of the axis? :.....
- b. Is the electric motor operating mechanism of the reversible motion type? :.....

- c. Can the electric motor operating mechanism be capable of being operated electrically locally and also electrically from a remote place? :.....

- d. Does the electric motor operating mechanism include provision for manual operation in case of emergency via hand-handle? :.....
- e. Is the supply circuit of the electric motor equipped with latching capability in order for the operating mechanism to complete its motion given the fact that the command pulse is 200ms in duration? :.....

f. Is the motion of the disconnecter stopped when the supply voltage to the electric motor is lost or the interlocking coil is deenergized? :.....
.....
.....

g. When the motion of the disconnecter is stopped due to voltage supply loss to the electric motor, does the disconnecter remain in the stopped position until a new command for motion is given? :.....
.....
.....
.....

h. Indicate the supply voltage for the electric motor :.....

i. Is the manual emergency operation carried out via rotary motion and reduction gear with a hand-handle? :.....
.....
.....

j. Is the hand-handle removable? :.....

k. Is the electric control circuit of the operating mechanism placed automatically out of service when the hand-handle is inserted for the manual emergency operation? :.....
.....

l. Are the parts of the hand-handle which come in contact with the human hands covered with an insulating material? :.....
.....

m. Can the opening in outer surface of the housing of the mechanism in which the hand-handle is inserted be secured with a padlock? :.....

n. Can the removable hand-handle be kept inside the housing of the operating mechanism? :.....

.....

o. Is the motor operated mechanism equipped with a rotary type selector switch of four positions as described in paragraph VII-16-f? :.....

.....

.....

.....

p. Does the offered disconnecter and its electric motor operating mechanism comply with the requirement of paragraph VII-16-g? :.....

.....

.....

g. Indicate compliance with paragraph VII-16-h? :.....

.....

.....

r. Is the electric motor operating mechanism equipped with limit switches which shall interrupt operation of the motor and the disconnecter's blade, when the blade has reached its final position? :.....

.....

.....

.....

- s. Is the electric motor operating mechanism equipped with an interlocking coil which shall be used for electrical interlocking between the disconnector and its corresponding circuit breaker? :.....
.....
.....
- t. Voltage of the interlocking coil? :.....
- u. Can the interlocking coil in its deenergized state prevent the electrical operation of the mechanism via an auxiliary contact and the manual operation by a mechanical block? :.....
.....
- v. Indicate the number and type of the auxiliary contacts of the electric motor operating mechanism :.....
.....
.....
.....
.....
- w. Size of control cables used in the wiring of the operating mechanism :.....
- x. Material of the housing of the operating mechanism and degree of protection as per IP :.....
.....
- y. Is the operating mechanism equipped with a spare terminal block of eight positions ? :.....
- z. Is the operating mechanism housing equipped with anti-condensation heaters, controlled by a thermostat ? :.....

- a1. Is the housing of the operating mechanism suitable for bottom entrance of cables ?
 b1. Are all necessary bolts, nuts, washers and brackets provided for the mounting of the housing of the operating mechanism ?
 c1. Is the manual operation carried out via rotary motion and reduction gear?
 d1. Are the circuits protected by miniature circuit breakers or fuses?
 e1. Supply voltage of the anti-condensation heaters
 f1. Auxiliary voltage of the circuits of the operating mechanism
 g1. Can the rotary selector switch be secured in its four positions with the aid of a lock?

26. Disconnectors' characteristics

- a. Numbers of poles
- b. Installation

- c. Rated voltage
- d. Power frequency withstand voltages
 - Phase to earth
 - Across the isolating distance

- e. Switching impulse withstand voltage
 - Phase to earth :
 - Across the isolating distance :
- f. Lightning impulse withstand voltages
 - Phase to earth :
 - Across the isolating distance :
- g. Rated frequency :
- h. Rated normal current :
- c. Rated short-time withstand current :
- j. Rated peak withstand current :
- k. Rated duration of short circuit :
- l. Rated static mechanical terminal load
 - Straight load :
 - Cross load :
 - Vertical force :
- m. Thickness of ice coating for which operation is possible :
- n. Mechanical endurance class :

27. Solid core post (column) Insulators characteristics

- a. Are the insulators of the outdoor, solid core, cylindrical post insulator type, with external fittings ? :
- b. Type of material of the cylindrical solid core post insulators ? :
- c. Color the porcelain? :
- d. IEC-60273 designation of the insulators :

- e. Power frequency withstand voltage, wet :.....
- f. Switching impulse withstand voltage, wet :.....
- g. Switching impulse withstand voltage dry :.....
- h. Lightning impulse withstand voltage :.....
- m. Height of the post insulator :.....
- n. Minimum creepage distance :.....
- l. Failing load
 - Bending :.....
 - Torsion :.....
 - Tension :.....
 - Compression :.....
- m. Bottom metal fitting pitch circle diameter :.....
- n. Maximum normal diameter of the insulating part :.....
- o. Top metal fitting pitch circle diameter :.....

28. Rotating (torsional) insulator characteristics:

- a. Type :.....
- b. Material of the insulator :.....
- c. Color of the porcelain :.....
- d. Power frequency withstand voltage :.....
- e. Switching impulse withstand voltage, wet :.....

- f. Switching impulse withstand voltage dry :.....
- g. Lighting impulse withstand voltage :.....
- h. Height of the insulator :.....
- i. Creepage distance :.....
- j. Maximum diameter of the insulating part :.....
- k. Failing load
 - Bending :.....
 - Torsion :.....
- l. Tension strength :.....
- m. Compression strength :.....
- n. Designation as per IEC 60273 :.....
- 29. Total weigh of the disconnecter :.....
- 30. Anti-condensation heater data
 - a. Rated voltage :.....
 - b. Power consumption :.....
- 31. Interlocking coil data
 - a. Rated voltage :.....
 - b. Power consumption :.....
- 32. Distance between the rotating insulator and its nearest column insulator :.....
 :.....
 :.....
- 33. Are the three (3) insulators of the pole of the disconnecter mounted on a common base frame? :.....

34. Does the two pieces arm (blade) of the disconnecter fold upon itself in a vertical position when found in the open position?

.....

.....

35. Distance between the two (2) column insulators of the disconnecter

.....

36. Are all terminal blocks suitable for 8mm² size conductors?

.....