



INDEPENDENT POWER TRANSMISSION OPERATOR SA  
Purchasing & Logistics Department

ENGLISH TEXT

INQUIRY No 408514  
SUPPLEMENT No 1  
DATE: 11.12.2015

Information: D. Lykogianni  
Telephone : 210 5192626  
E-mail : [d.lykogianni@admie.gr](mailto:d.lykogianni@admie.gr)

OBJECT: 20kV VACUUM CAPACITOR SWITCHES, 20kV DRY TYPE DAMPING  
REACTORS, 24kV CURRENT TRANSFORMERS

---

This Supplement No1 of the above mentioned Inquiry is published for the following reasons :

1. The paragraph III.5.d of Technical Description is modified as follows:  
<< The height of the reactor including insulator shall be 700mm+10% maximum>>.
  2. Along the evaluation data of the reactors, which will be submitted with the offers, the following shall be also included:
    - a. Declaration that they have sold to Power Electrical Companies, at least 50 reactors of  $\geq 24\text{kV}$  and  $\geq 150\text{A}$  during the last four (4) years stated full details of the user (Address, telephone, Fax, e-mail)
    - b. Users confirmation verifying that the reactors have been installed and operate satisfactorily without problems, for the last two (2) years. In these declarations will be referred the quantity , the time of purchase and the time of installation, otherwise the offers will be rejected as incomplete.
    - c. If the requested equipment have been installed and operate satisfactorily in the Greek transmission System in the last 10 years, the above data (a) and (b) are not required.
  3. Regarding the type tests of the reactors, we note that bidders have to submit the relevant type test certificates which are referred in the corresponding technical description (TD -7/2 ), otherwise their bids will be charged with the cost which should be declared in their financial offer.
  4. The closing date of submission of offers is extended as follows:  
  
INITIAL CLOSING DATE OF INQUIRY : 12.01.2016 and hour 10:00'  
NEW CLOSING DATE MODIFIED BY  
THIS SUPPLEMENT No 1 : 22.01.2016 and hour 10:00'
  5. All Terms and Conditions of the Initial Inquiry except as expressly modified by this Supplement No 1, will remain in full force and effect.
-